



Clean Flow™ Tabs

Application Instructions

CENTRAL AND PORTABLE AIR CONDITIONERS

For initial applications, place two or more tablets in the condensate drain tray for each ton (12,000 Btu) of air conditioning. Position the tablet(s) at a point furthest from the drain to assure complete treatment. Additional applications should be done monthly at the rate of one tablet per ton.

WHOLE HOME AND CONSOLE DEHUMIDIFIERS

Place one or two tablets in the water tank. Repeat application each time tank is emptied. Periodically rinse tank and wipe clean.

REFRIGERATORS

Drop one tablet into the condensate drain pan. Position the tablet so that the condensing water drips over it. Rinse and wipe pan after emptying. Repeat application when tablet has completely dissolved.



CAUTION: KEEP OUT OF REACH OF CHILDREN.

Non-toxic when properly used. Not to be used in potable water. Harmful if swallowed. Avoid contact with eyes, skin and clothing. In case of contact with skin, flush with water. For eyes, flush with water and seek medical attention.

NON-WARRANTY

All data, statements and recommendations contained herein are based on the best information available and are believed to be reliable. However, no warranty, either expressed or implied, is made concerning the application of the product since the customer's use of it cannot be controlled.

MANUFACTURED FOR:

SimpleAir Care, LLC
P.O. Box 357
Columbus, TX 78934
855.342.3732
SimpleAirCare.com